

BS 7976-2 Test Certificate

SafeKerb Supagrip

Test conducted 12/08/19 by Ben Powers, at Grip Consulting, to UKSRG Guidelines

Image 1. Pendulum tester in-situ



Image 2. Test surface



Pendulum Test Results

Slider #96/4S

Direction	Condition	Pendulum Test Value					Median PTV	Lowest PTV	Slip Risk Classification
Principal	Dry	70	68	72	70	72	70	61	Low
45°		69	72	71	69	70	70		
90°		61	61	61	61	61	61		
Principal	Wet	51	53	51	53	52	52	36	Low
45°		52	52	53	53	52	52		
90°		36	36	36	36	36	36		

Results generated using a BS 7976 Munro Portable Skid Tester, serial number 0852. The device was calibrated by KSS on 05/03/19, certificate number CN681. The above results have been classified in accordance with the latest UK Slip Resistance Group Guidelines (Issue 5, 2016) and current UK Health & Safety Executive guidance.

Rz Surface Roughness Results

Direction	Principal				45°		90°		Mean Rz Value (µm)	
Rz Value (µm)									n/a	

Results not recorded as the surface presents a macro-profile, particulate based profile, or is otherwise unsuitable for measurement with the roughness meter.

Declaration

The above assessment was carried out by Grip Consulting adhering to the UKSRG and HSE guidelines on pedestrian slip risk assessment. The results given are accurate representations of data acquired on site. The results have been interpreted to give slip risk classifications based on parameters recommended by the UKSRG and HSE.

Signed:



Ben Powers, BSc (Hons) TechIOSH MAE
Slip Risk Consultant
Grip Consulting
12/08/19